

Appearance



Product: DSPS010001 Deckplate

Supplier: Cobra Europe

Test: Compliance with BS EN 14041

Conclusion: "Static dissipative"
vertical resistance $\leq 10^9 \Omega$

Date of test: 13th September 2019

Conditions: 50 %rh \pm 5%rh 23 \pm 2 °C

Results:	Parameter	Result (Ω)			Method
	Vertical resistance	(Max.)	(Min.)	(Mean)	
		1.1×10^8	8.2×10^7	9.8×10^7	EN1081

Certificate No: C2019-0311-1

Full details of the trial, results and recommendations are documented in
ESL Report No. 2019-0311

Dr Jeremy Smallwood
Managing Director and Principal Consultant

